

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION
OFFICE OF THE STATE FIRE MARSHAL
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM

LISTING SERVICE

LISTING No. 7270-0447:130

Page 1 of 1

CATEGORY: Heat Detector

LISTEE: ESL/Sentrol, 12345 SW Levetron Drive, Tualatin, OR 97062
Contact: Gene Hukkanen (503) 691-7369

DESIGN: Models 713-5U and 713-6U heat detectors. Model 713-5U is combination 135°F fixed temperature and rate-of-rise type. Model 713-6U is rate-of-rise type. Refer to listee's data sheet for detailed product description and operational considerations.

INSTALLATION: In accordance with listee's printed installation instructions, applicable codes and ordinances and in a manner acceptable to the authority having jurisdiction.

MARKING: Listee's name, model number, ratings, and UL label.

APPROVAL: Listed as heat detectors for use with Models 701E, 701U, 702E and 702U bases (CSFM Listing No. 7300-0447:133) and separately listed compatible fire alarm control units.

10-25-95



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

Date Issued: **APRIL 2, 2001**

*Listing Expires **June 30, 2002***

Authorized By: **BEN HO**, Supervising Deputy
Program Manager